

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7150-1439:100 Page 1 of 1

CATEGORY: Boxes/Pull Stations

LISTEE: Killark Electric Mfg., 3940 Martin Luther King Dr, St. Louis, MO 63113
Contact: Thomas Michalski (314) 531-0460 Fax (314) 531-7164

DESIGN: Models XAL and XAS noncoded fire alarm boxes, followed by 1, 2, 3, 4, 5, 6, 13, 14, 41, 42, 43, 44, 45, or 46, followed by 1, 2, 3, 4, 5, 6, 7, or 8. Conduit sizes in 1/2", 3/4" and 1". Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 6 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as fire alarm boxes for use with separately listed compatible fire alarm control panels. Suitable for use in Class I, Group C and D, and Class II, Groups E, F, and G, and Class III hazardous locations.

03-23-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager